

**Comments of the Manufacturers of Emission Controls Association on
the U.S. Environmental Protection Agency's Emission Standards for
Stationary Diesel Engines Advance Notice of Proposed Rulemaking**

Docket ID No. EPA-HQ-OAR-2007-0995

February 25, 2008

The Manufacturers of Emission Controls Association (MECA) is pleased to provide comments in response to the U.S. Environmental Protection Agency's (EPA) Emission Standards for Stationary Diesel Engines Advance Notice of Proposed Rulemaking (ANPRM). We commend the agency for its continuing efforts to develop and implement effective emission control standards for major sources of air pollution such as this category of engines.

MECA is a non-profit association made up of the world's leading manufacturers of mobile source emission control equipment for automobiles, trucks, buses, and off-road vehicles, as well as stationary internal combustion engines. MECA member companies have over 35 years of experience and a proven track record in developing and commercializing exhaust emission control technologies for these types of engines.

Available PM Emission Control Technologies for Stationary Diesel Engines

The main technologies that have been successfully used to reduce diesel PM from stationary diesel-fueled engines are diesel particulate filters (DPFs) and diesel oxidation catalysts (DOCs). Flow-through filters (FTFs) can also be used to reduce diesel PM from stationary diesel-fueled engines.

Diesel particulate filters (DPFs) have been successfully used in many stationary applications, including prime stationary and emergency standby engines. The key component of a DPF is typically a porous ceramic wall-flow material (or sintered metal material), which permits gases in the exhaust to pass through but traps the PM. PM emission reductions in excess of 85 percent are possible, depending on the engine's baseline emissions, fuel sulfur content, and duty cycle. In addition, up to a 90 percent reduction in carbon monoxide (CO) and a 95 percent reduction in hydrocarbons (HCs) can also be realized with catalyst-based DPFs operated on ultra-low sulfur diesel fuel. Since filters will accumulate soot over time, they must be cleaned out ("regenerated") intermittently. Both passive (DPF systems that regenerate themselves using only the exhaust gas stream) and active (DPF systems that use additional energy inputs to facilitate regeneration) techniques can be used. In addition, the use of a fuel-borne catalyst (FBC) in conjunction with uncatalyzed or lightly catalyzed DPF systems can help provide reliable filter regeneration, especially at lower exhaust temperatures and/or elevated fuel sulfur levels.

Diesel oxidation catalysts (DOCs) are another important emission control strategy for reducing pollution from stationary diesel engines. Typically using a very light

loading of platinum catalyst on a monolithic support, they are able to oxidize CO, HC, and the soluble organic fraction (SOF) of PM in a diesel engine's exhaust stream. DOCs installed on engines running 500 ppm or less sulfur fuel have achieved total particulate matter reductions of 20 to 50 percent, hydrocarbon reductions of 60 to 90 percent (including those HC species considered toxic), and significant reductions of carbon monoxide, smoke, and odor.

Flow-through filter (FTF) technology is another available method for reducing diesel PM emissions from stationary diesel engines. FTFs employ catalyzed metal wire mesh structures or tortuous flow, metal foil-based substrates with sintered metal sheets to reduce diesel PM. Technologies verified to date employ catalyst coatings and/or fuel-borne catalysts to oxidize soot. Flow-through filters are capable of achieving PM reductions of about 30 to 75 percent. The filtration efficiency of an FTF is lower than that of a DPF, but the FTF is much less likely to plug under unfavorable conditions, such as high PM emissions and low exhaust temperatures.

Diesel PM emission reductions can also be realized through the use of cleaner diesel fuels, biodiesel, or alternative fuels. The use of ultra-low sulfur diesel (ULSD) fuel can result in modest PM reductions by itself and will enable the optimum use of advanced emission control technologies (e.g., catalyst-based DPFs, catalyst-based FTFs, and DOCs). EPA has already finalized rules that require the use of ULSD on off-road diesel engines starting in 2010. The use of ULSD on stationary diesel engines, however, is only currently required for those stationary engines that are constructed, reconstructed, or modified after July 11, 2005. As part of this present rulemaking effort, MECA believes that EPA should require all stationary diesel engines to operate on ULSD no later than the 2010 requirement associated with off-road diesel engines.

Significant emission reductions for oxides of nitrogen (NO_x) may also be obtained in combination with these aforementioned PM emission control strategies. Selective catalytic reduction (SCR) has long been the technology of choice for NO_x emission reduction in industrial processes and stationary power generation applications. More recently, SCR systems have been developed for mobile source applications. SCR systems work by chemically reducing NO_x to nitrogen using the addition of a reductant (e.g., ammonia, of which urea is the most common) to the exhaust gas stream. NO_x reduction efficiencies for SCR can exceed 90 percent in steady-state operating modes that match the SCR catalyst temperature window.

Feasibility of Emission Control Technologies for Stationary Diesel Engines

Based upon current real-world experience, results from demonstration programs, and conversations with MECA technology vendors, MECA believes that exhaust emission controls are a proven technology option for reducing emissions from in-use stationary diesel engines, including older (manufactured before 1996) and large (300 hp and greater) in-use stationary diesel engines. One of the key sources of information in support of the technical feasibility of applying emission controls to stationary diesel engines is the work conducted by the California ARB in support of its airborne toxic

control measure (ATCM) for stationary compression-ignition engines (promulgated in November 2004). In the ATCM, diesel retrofits are one of the compliance options identified for reducing PM emissions from existing stationary diesel engines used in prime applications and emergency stand-by applications. This ATCM requires in-use stationary diesel engines >50 hp used for either prime applications or emergency stand-by applications (operated for 51-100 hours/year) to meet a 0.01 g/bhp-hr PM standard or to reduce PM emissions by 85 percent or more by no later than January 1, 2009 for 1996 or older engines (or by January 1, 2008 for owners of three or fewer engines). Level 3 (at least 85 percent or greater PM reduction) verified retrofit technologies, such as verified DPFs, provide the required PM reductions to meet these ARB ATCM requirements. (Note that California requires all stationary diesel engines to be fueled with ultra-low sulfur diesel fuel with a maximum sulfur content of 15 ppm.) For both small (≤ 50 hp) and larger engines (>50 hp), ARB determined that the PM emission standards under the ATCM were technologically feasible, due to: 1) successful emission control experience with similar-sized off-road engines that had to meet the same PM standards and 2) successful operation of approximately 50 stationary diesel-fueled engines with DPFs in California (the engines controlled represent a wide range of engine types, model years, horsepower ratings, and applications).

As of February 2008, there are six different Level 3 DPF systems (both active and passive regeneration) and one Level 2 (at least 50 percent or greater PM reduction) FTF system that have been verified by ARB for stationary engines. (A complete listing of ARB-verified retrofit technologies for stationary diesel engines is available at: www.arb.ca.gov/diesel/verdev/vt/stationary.htm.) Additional verifications of retrofit DPF technologies for stationary engines are expected in the future. Under the current list of verifications, although no technology has been verified for stationary diesel engines older than 1996, it should be noted that two Level 3 technologies and one Level 2 technology have been verified for use on stationary diesel engines with a PM emission rate of up to 0.4 g/bhp-hr, a PM level which is characteristic of older stationary diesel engines.

As EPA is aware, ARB and EPA have also verified a large number of Level 3 DPF technologies for mobile on-road and nonroad applications (a complete listing of ARB-verified retrofit technology – Levels 1-3 – for mobile source applications is available at: www.arb.ca.gov/diesel/verdev/vt/cvt.htm; EPA's list of verified retrofit technology products is available at: www.epa.gov/otaq/retrofit/verif-list.htm). In many cases, similar types of DPF retrofit solutions for mobile nonroad sources can be engineered for many stationary diesel engine applications.

In discussions with MECA technology vendors, important design parameters to consider when determining the feasibility of installing an emission control system on a particular stationary diesel engine include: filter volume (which is tied in part to the engine-out PM levels and engine backpressure limits), engine operating temperature (the temperature must be hot enough to ensure regeneration of the collected soot), the NO_x-to-PM ratio of the engine exhaust stream, and the amount of lube oil consumed (too much lube oil will require more frequent cleaning of the filter).

Retrofit Experience with Stationary Diesel Engines

The most comprehensive information on the application of PM exhaust emission control technology to in-use stationary diesel engines can be found in ARB's September 2003 Staff Report in support of its ATCM for stationary compression-ignition engines. In the report, ARB provides a thorough list of in-use emergency standby engines and prime stationary engines using emission control systems (mostly DPFs) in California. The retrofit devices were installed on stationary engines ranging from model years 1993 to 2002. The list shows numerous DPF installations on large engines rated above 600 kW, including Caterpillar 3516 engines rated in the 1490-2120 kW range. Operating experience with these large engine DPF systems has been generally good, with DPFs providing 85 percent or more reductions in particulate matter compared to uncontrolled levels. ARB interviewed several of the stationary engine operators and most stated that the retrofit devices met all regulatory requirements and required little or no extra maintenance.

In July 2005, the California Energy Commission published a report, *Air Quality Implications of Backup Generators In California*, detailing the emission performance of back-up diesel generators with a variety of power ratings equipped with exhaust emission controls, including DOCs, passive DPFs, and active DPFs (a copy of this report is available at: www.energy.ca.gov/pier/final_project_reports/CEC-500-2005-049.html). The DPFs evaluated in this program were again found effective in reducing PM emissions by more than 85 percent compared to uncontrolled baseline levels. The results of the demonstration program showed successful application of DPFs, DOCs, and emulsified fuels on engines ranging in age from two to 18 years old. Durability testing of the DPF and DOC systems for intermittent cold start and extended high load operation indicates that these technologies are effective for generator applications and may be effective for other steady-state stationary engine applications as well.

In September 2005, J. Cloud Inc., a rock-crushing operation in El Cajon, California, installed DPF systems on their pre-1996 Caterpillar 3408 (0.2 g/bhp-hr PM) and Caterpillar 3306 (0.3 g/bhp-hr PM) engines. The 536-hp Caterpillar 3408 engine drives a hydraulic pump that powers a rock crusher and the 430-hp Caterpillar 3306 engine drives a generator that provides power for a conveyor. Each DPF system contains two filters and each was designed to match the engine size and exhaust conditions of the respective engine. The site operates eight hours a day for five days a week. The DPF systems have achieved PM reductions of 85 percent and CO reductions of 80 percent. In addition, the DPF systems run at a backpressure of approximately 15" water column at full load and have only been cleaned once at 1,200 hours to remove accumulated ash from the filters.

A December 2005 technical paper from Johnson Matthey, *The Simultaneous Reduction of NO_x, PM, HC and CO from Large Stationary Diesel Engines Using SCR and Particulate Filters*, detailed the installation of DPF+SCR systems on two large stationary engines used at Snow Summit Mountain Resort in southern California. The

two engines were Cummins QSK78-G6 diesel engines, which powered two 2 MW generators. Source test results showed PM reductions of greater than 90 percent and NOx reductions of greater than 94 percent.

Outside of California, the New Jersey Department of Environmental Protection (NJDEP), in collaboration with the Stevens Institute of Technology and an emission control technology manufacturer, is currently conducting a demonstration project to install a DPF system on a 500 kW electric diesel generator located at the Jersey City Total Energy Plant.

In other countries, Taiwan has had extensive experience with the retrofit of stationary diesel engines. Power outages are frequent in Taiwan, so standby generators used for emergency back-up power are an important part of the country's infrastructure. DPFs have been successfully installed on these generators. For example, Taiwan Semiconductor Manufacturing installed DPFs on 14 standby generators (2 MW engines) in 2001, which has resulted in a greater than 90 percent reduction in PM.

Several MECA member companies have experience with the application of DPFs to existing stationary diesel engines. DPFs have been successfully applied to stationary engines as small as 20 kW to very large installations on emergency back-up or prime power generators with several megawatts of power. This experience base includes both passively regenerated DPF systems and actively regenerated DPF systems (e.g., with electrical heating or fuel burner-type regeneration), as well as fuel-borne catalyst regenerated DPF systems.

In terms of retrofit experience in the mobile sector that can be applied to stationary engines, there is a wealth of experience where DPFs have been cost-effectively installed on nonroad vehicles. DPFs have been successfully installed and used on mining, construction, and materials handling equipment where vehicle integration has been challenging. These nonroad applications include the use of both passive and active filter regeneration strategies. Active nonroad DPF options include diesel fuel injection strategies, engine throttling strategies, the use of electrical heating elements, and fuel burners. Over 20,000 active and passive systems have been installed on nonroad applications as either original equipment or as a retrofit worldwide. DPFs, many employing active regeneration strategies, have also been installed on over 100 locomotives in Europe since the mid-1990s.

The retrofit of oxidation catalysts on diesel engines has been taking place for well over twenty years in the nonroad vehicle sector. Over 250,000 oxidation catalysts have been installed in underground mining and materials handling equipment. DOCs have also been installed in marine diesel applications (e.g., ferries), which have duty cycles that closely mimic stationary engine operation.

The commercial use of SCR systems for the control of NOx from stationary engines has been around since the mid-1980s in Europe and since the early 1990s in the U.S. Since 1995, one MECA member company specifically has installed over 400 SCR

systems worldwide for stationary engines with varying fuel combinations. In general, several MECA member companies have proven experience in the installation of SCR systems for both stationary and mobile engines, as well as the installation of integrated DPF+SCR emission control systems for combined PM and NO_x reductions.

Costs of Retrofitting Stationary Diesel Engines

As part of their September 2003 stationary CI engine ATCM staff report, ARB conducted an economic analysis to determine the cost to businesses to meet the ATCM. ARB concluded that the majority of the costs would be borne by prime engine owners, while, in many cases, owners of emergency standby engines would have no cost or net savings due to the reduced operating hours. The total costs for a typical prime stationary engine (rated at 590 hp operated for 1,040 hours per year) retrofitted with a DPF were about \$22,400 for equipment and installation, \$100 for reporting, and \$550 per year for ash cleaning/maintenance. The total cost for the same engine with a DOC was about \$6,250 (no annual maintenance). ARB estimated the overall cost-effectiveness of the proposed ATCM to be about \$15 per pound of diesel PM reduced, considering only the benefits of reducing PM. However, since the ATCM would also reduce reactive organic gases (ROG) and NO_x emissions, ARB staff allocated half of the costs of compliance against these benefits, which resulted in cost-effectiveness values of \$8/lb of PM and \$1/lb of ROG plus NO_x reduced.

Although diesel PM is not included on the list of EPA's hazardous air pollutants (HAPs), EPA considers diesel emissions to be a serious public health concern and a possible carcinogen. Given that approximately 30 percent of diesel PM is made up of soluble organic fraction and given that the SOF consists of condensed volatile compounds, many of which are on the HAP list, it is important to consider the multi-pollutant co-benefits that emission controls can provide in reducing CO, HCs, and SOF. An inexpensive device such as a DOC can effectively remove the SOF from the carbon particles, offering significant HAP benefits at a reasonable cost.

Conclusion

We commend EPA for taking an important first step to reduce emissions from in-use stationary diesel engines, especially older and large non-emergency engines. We believe the current real-world experience and results from demonstration programs indicate that diesel PM control technologies are capable of providing a wide range of reduction levels for these particular engines and for in-use stationary diesel engines in general.

DPFs, in particular, have demonstrated to be very effective in reducing PM emissions from both mobile and stationary diesel engines. The combination of using ultra-low sulfur diesel fuel with high-efficiency DPFs (e.g., DPFs that use wall-flow ceramic filters) provides the maximum reduction in PM emissions and additional co-benefits of significant reductions in toxic HC emissions and CO when catalyst-based DPFs are employed. MECA believes DPFs should be installed on in-use stationary diesel

engines wherever technically feasible and that these engines should be fueled with ultra-low sulfur diesel fuel to provide the maximum flexibility in the design of effective retrofit DPF emission control solutions. MECA believes that the use of ULSD in combination with retrofit DPFs on existing stationary diesel engines can be implemented in the 2010 timeframe on both prime and emergency stand-by engines with power ratings of 50 hp or greater. In addition, the combination of DPFs with SCR systems can be an effective solution for delivering combined PM and NOx reductions from in-use stationary diesel engines. In situations where DPFs are not technologically feasible, DOCs should be considered as an alternative option to help achieve at least a minimum level of PM control from applicable stationary diesel engines.

MECA and its member companies look forward to working with EPA, the engine and equipment manufacturers, end-users, and others in putting together a proposed rulemaking.

Contact:

Joseph Kubsh
Executive Director
MECA
1730 M Street, NW
Suite 206
Washington, D.C. 20036
(202) 296-4797
jkubsh@meca.org